



BRUHATH BANGALORE MAHANAGARA PALIKE

Office Of The Medical Officer Health, Rajarajeshwari Nagar Zone

Kengeri Sub Division , Kengeri, Bengaluru-560060.

No: BBMP/KEN/MOH/PR/83/2025-26

Date : 27/06/2025

TO WHOMSOEVER IT MAY CONCERN

It is certified that an inspection team headed by **Dr. ARUN KUMAR T**, Medical Health Officer, Kengeri Division, R R Nagar Zone, BBMP, Bangalore-60, inspected the **AGASTHYA VIDYANIKETHAN** located at No.170/3, 6TH Block, Off 100 feet Road, Sir M V Layout, Ullalu Upanagara, Bengaluru-560110. on Date: 25/06/2025 and found that they have safe drinking water facilities for the students and members of staff of the institution and is maintaining the Health and Hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

The above is valid for a period of **27.06.2025 to 26.06.2026**.

Signature with Seal:



Dr. ARUN KUMAR T,

MEDICAL HEALTH OFFICER

ಆರೋಗ್ಯ ಮತ್ತು ಕುಟುಂಬ ಕಲ್ಯಾಣ ಇಲಾಖೆ,

ಕೆಂಗೇರಿ ವಿಭಾಗ, ಕೆಂಗೇರಿ,

ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ,

Rajarajeshwari Nagar Zone,

Bangalore-60

To,

AGASTHYA VIDYANIKETHAN

No.170/3, 6TH Block,

Off 100 feet Road, Sir M V Layout,

Ullalu Upanagara, Bengaluru-560110.

NOTARY STAMP NOT AFFIXED
DUE TO THE KARNATAKA GOVT. HAS
DISCONTINUED THE NOTARY STAMP
FROM : 01-04-2003

ATTESTED BY ME

L. PUTTARAJU, B.A., LL.B.
ADVOCATE & NOTARY
Office : Shop No. 4, # 32, Aravinda Complex,
Kanakapura Main Road, Vivekananda Colony,
J.P. Nagar Post, BENGALURU - 560 078.

21 JUL 2025

MEDICAL HEALTH OFFICER

KENGERI DEVISION

RAJARAJESHWARI NAGARA, JONE

BRUHATH BANGALORE MAHANAGARA PALIKE,

BANGALORE -60





RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- Agasthya Vidyanikethan Sy No 170/3, Ullalu Village, vishwaneedam Post, Yeshwanthpura Hobli, Bangalore.				Report date: 27/06/2025 Report Number: 0018 Reference: TRF Sample code: 0018 Date of Sample collection: 26/06/2025 Analysis start date: 26/06/2025 Analysis completion date: 27/06/2025 Sample quantity: 1 Liter	
Sample Particulars: R O water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.1	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	230	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	140	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	84.0	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	48.4	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	8.1	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	4.9	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	9.4	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	10.5	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.4	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	14.0	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	0.0	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the Acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: <u>Megha K.S.</u> Senior Analyst/Junior Analyst			Authorized Signatory: <u>Pavithra B.S.</u> Technical Manager: Pavithra B.S.		



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---

Page 1 of 1

